

SSO Notification List

September 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	9/1/2012	500 E. 33rd St	21218	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	N/A	Needs a plumber	143816
2	9/1/2012	914 E. 37th St	21218	Rags & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143820
3	9/4/2012	123 W. Lanvale St	21217	Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143886
4	9/4/2012	909 N. Charles St	21201	Grease & Trash	WWO	Inner Harbor	2:25	11:00AM - 1:25PM	Gray Colored Water	435	Electric Machine relieved House Connection choke	Turn over to CCTV	143898
5	9/4/2012	932 Seagull Ave	21225	Grease & Debris	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Grease & Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	143953
6	9/4/2012	Webster St. & Key Hwy	21202	Rags & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Small Amount of Paper	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	143893
7	9/5/2012	3341 W. Belvedere Ave	21215	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144003
8	9/5/2012	5656 The Alameda	21239	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144002
9	9/5/2012	Cardenas & Chesterfield	21213	Rags & Trash	WWO	Herring Run	10:00	10:00AM - 8:00PM	Brown & Gray Colored Water	9,000	Pressure Jet relieved Mainline choke	Turn over to CCTV	143970
10	9/6/2012	1530 E. Biddle St	21213	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144025
11	9/6/2012	2325 Hollins St	21223	Rags	WWO	Gwynns Falls	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Paper Debris & Feces	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144044
12	9/6/2012	2807 Overland Ave	21214	Rags, Trash & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144051
13	9/6/2012	4811 Midline Rd	21206	Debris	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Debris removed from Cleanout by Consumer	N/A	144033
14	9/7/2012	218 E. Lexington St	21201	Pipe Break	DWO	Inner Harbor	3:00	4:00PM - 7:00PM	Sewer Water	360	Pumped down Terminal Manhole	Contractor to excavate & repair	144117
15	9/7/2012	4811 Midline Rd	21206	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144073
16	9/8/2012	845 Glen Allen Dr	21229	Rags & Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144141
17	9/9/2012	4120 Kathland Ave	21207	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144168
18	9/10/2012	2300 Cylburn Ave	21215	Rags & Grease	DWO	Gwynns Falls	3:00	11:00AM - 2:00PM	Heavy Gray Water	4,500	Pressure Jet relieved Mainline choke	Turn over to CCTV	144204
19	9/11/2012	817 Stoll St	21225	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144261
20	9/11/2012	400 Saugusta Ave	21229	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144301
21	9/11/2012	6600 Boston St	21224	Rags & Grease	DWO	Dundalk	1:25	9:35PM - 11:00PM	Heavy Gray Water	425	Pressure Jet relieved Mainline choke	Turn over to CCTV	144305
22	9/12/2012	3550 Potee St	21225	Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	144315
23	9/14/2012	2 Hadley Sq. North	21218	Rags & Trash	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144412
24	9/14/2012	1830 Aliceanna St	21202	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around sidewalk	Evidence of Overflow	Left plumber notice to locate or install cleanout	N/A	144442
25	9/14/2012	4999 Perring Pkwy	21239	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	144441
26	9/15/2012	703 N. Carey St	21223	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144464
27	9/16/2012	4520 Schenley Rd	21210	N/A	DWO	Jones Falls	2:00	2:00PM - 4:00PM	Grease & Rags	240	Pressure Jet relieved Mainline choke	Turn over to CCTV	144479

SSO Notification List

September 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
28	9/16/2012	4903 St. Gemma	21229	Grease & Water	DWO	Gwynns Falls	1:45	9:45PM - 11:30PM	Gray Water	210	Pressure Jet relieved Mainline choke	Turn over to CCTV	144507
29	9/16/2012	5800 York Rd	21212	Rags & Grease	DWO	Herring Run	2:08	11:38AM - 1:30PM	Grease & Rags	224	Pressure Jet relieved Mainline choke	Turn over to CCTV	144484
30	9/17/2012	2218 Hill House Rd	21217	Rags & Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	144560
31	9/17/2012	3511 4th St	21225	Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144432
32	9/18/2012	307 Rossiter Ave	21212	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144622
33	9/19/2012	219 E. North Ave	21202	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144662
34	9/19/2012	1900 N. Howard St	21201	Rags & Grease	DWO	Jones Falls	18:22	9/19/12 3:38PM - 9/20/12 10:00AM	Heavy Gray Water	5,510	Pressure Jet relieved Mainline choke	Turn over to CCTV	144663
35	9/19/2012	2400 Cylburn Ave	21215	Rags & Roots	DWO	Gwynns Falls	1:33	10:08AM - 11:47AM	Heavy Gray Water	2,475	Pressure Jet relieved Mainline choke	Turn over to CCTV	144640
36	9/20/2012	3020 Frisby St	21218	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Small Amount of Paper	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144692
37	9/20/2012	4403 Frederick Ave	21229	Rags & Grease	DWO	Gwynns Falls	2:14	12:26PM - 2:40PM	Heavy Gray Water	670	Pressure Jet relieved Mainline choke	Turn over to CCTV	144707
38	9/22/2012	1282 Battery Ave	21230	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Wet on sidewalk	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144783
39	9/22/2012	3303 Woodring Ave	21234	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144793
40	9/23/2012	462 Round Hill Rd	21218	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144825
41	9/25/2012	1307 N. Woodington Road	21229	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144987
42	9/25/2012	4801 Lorelly Ave	21206	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144956
43	9/26/2012	4801 Lorelly Ave	21206	Rags, Trash & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	144980
44	9/27/2012	4908 Saint Gemma Rd	21229	Debris	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	145073
45	9/30/2012	410 E. 31st. St	21218	Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	145173
46	9/30/2012	1147 Monroe Cir	21225	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	145162
				# WWO	23				TOTAL	24,049	EVIDENCE ONLY	35	