

**SSO Notification List**

**April 2014**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	4/1/2014	3426 Elmley Ave	21213	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	N/A	Turned over for main to property	191005
2	4/1/2014	Stoney Rd & Linkwood Rd	21210	Rags, roots, debris	DWO	Jones Falls	0:20	1:25 PM -1:15 PM	Gray water	40	Rel 200ft pressure machine hose	UAMD CCTV	191036
3	4/1/2014	1720 N Longwood St	21216	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Ran elec mach 30ft. Also pressure truck flush machine	UAMD	191018
4	4/1/2014	1703 Bloomingdale Rd	21216	Roots, debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Pressure truck flush mainline 125ft pressure hose	UAMD	191012
5	4/2/2014	1709 Chilton St	21218	Roots	WVO	N/A	0:50	10:00 AM - 11:00 AM	Paper	120	Relieved with H cutter and electric machine	UAMD	191094
6	4/2/2014	2205 W Baltimore St	21223	Rocks	WVO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper debris	Evidence of Overflow	Ran 8ft Elec-Machine, left plumber notice bad bottom	UAMD	191111
7	4/3/2014	1824 McCulloh St	21217	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around cleanout	Evidence of Overflow	Used elec-mach	UAMD	191204
8	4/3/2014	6214 Fairdel Ave	21206	Roots, grease	WVO	Herring Run	1:45	10:45 AM - 12:30 PM	Small amount of paper	525	Jetted line with vac con	UAMD	191171
9	4/3/2014	2505 Brookfield Ave	21217	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Pressure jet fluhs & cleaned sanitary mainline	UAMD	191194
10	4/4/2014	2800 Rosalind Ave	21215	Rags, roots, debris	WVO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Ran elec. mach. Also flush house conn choke rel. pressure hose	UAMD	191234
11	4/4/2014	4105 McKendree Pl	21215	Rags, grease	WVO	N/A	0:50	8:00 PM - 9:00 PM	Water around manhole	30	Used sewer jet	UAMD	191284
12	4/4/2014	4118 Fernhill Ave	21215	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper, wet around cleanout	Evidence of Overflow	Used elec. mach.	UAMD	191286
13	4/5/2014	4005 Edmondson Ave	21229	Rags debris	WVO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Rel 30ft Elec Machine cable	UAMD	191305
14	4/5/2014	4701 N Charles St	21210	Rags, roots	DWO	Jones Falls	1:24	1:40 PM - 3:04 PM	Gray water and debris	168	Pressure truck flush main line, also complaint truck ran CCTV mainline	UAMD	191308
15	4/5/2014	2617 Woodland Ave	21215	Rags, roots, infiltration	DWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Pressure jet relieved the H/C choke	UAMD	191234
16	4/6/2014	2201 Homewood Ave	21218	Rags, debris	DWO	N/A	4:12	10:48 AM - 3:00 PM	Gray water toilet paper	252	Pressure truck rel main line choke 350ft pressure hose	UAMD	191333
17	4/6/2014	Greenspring Ave & Park Hill Ave	21211	Rags, debris	DWO	N/A	2:38	11:04 AM - 1:42 PM	Gray water	316	Pressure truck rel main line choke 300ft pressure hose	UAMD	191340
18	4/6/2014	2904 Rueckert Ave	21214	Infiltration	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Turned over to health dept. under ID#252065	N/A	122108
19	4/6/2014	5012 Wetheredsville	21207	Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved the H/C choke	UAMD	191358
20	4/7/2014	845 E Pontiac Ave	21225	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper around clean out	Evidence of Overflow	Used elec. mach.	UAMD	191459
21	4/7/2014	3606 Menlo Dr	21215	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 45ft of 6in T/O for CCTV	N/A	191404
22	4/8/2014	9 N Wheeler Ave	21223	Rags, grease	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet around clean out	Evidence of Overflow	used elec. mach. lefters plumber note to remake old choke trap	UAMD	191537
23	4/8/2014	3400 Reisterstown Rd	21215	Vandalism	WVO	Patapsco	1:41	3:10 PM - 4:51 PM	N/A	202	Relieved M/L choke with pressure truck 150ft of 8in, san M/L T/O for CCTV	CCTV	191518
24	4/8/2014	Spelman Rd & Bethune Rd	21225	Rags, Grease	WVO	Patapsco	3:26	11:49 AM - 3:15 PM	Heavy gray water	3090	Relieved M/L choke with pressure truck 300ft of 15in T/O for CCTV	N/A	191507
25	4/9/2014	2805 Steele Rd	21209	Rags, roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved M/L choke with pressure truck 50ft of 8in san M/L CCTV	N/A	191542
26	4/9/2014	3405 Garrison Blvd	21215	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved h/c choke	UAMD	191613
27	4/10/2014	3300 Clipper Mill Rd	21211	Rags, vandalism	DWO	Jones Falls	22:53	04/10/14 4:07 PM - 04/11/2014 3:00 PM	Heavy gray water	6865	Relieved M/L choke with pressure truck 150ft of 8in No CCTV	N/A	191780
28	4/10/2014	Bonniewev Dr & Western Run Dr	21209	Rags, roots, ground	DWO	Jones Falls	3:00	2:00 PM - 5:00 PM	Heavy Gray Water	360	Relieved house conn choke with pressure truck 50ft of 6in T/O for CCTV	CCTV	191738
29	4/11/2014	72 S Morley St	21229	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 30ft T/O for CCTV	N/A	191804
30	4/12/2014	1815 Ruxton Ave	21216	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Not relieved, ran 75ft of elec mach flush & clean 250ft of 8in san M/L T/O to flush house connection in the AM	N/A	191857
31	4/12/2014	2600 Insulator Dr	21230	Pipe break, grease, debris	DWO	Patapsco	4:20	5:40 PM - 10:00 PM	Heavy gray water	520	Relieved house conn choke 5ft of 2" lnr no CCTV	N/A	191870
32	4/12/2014	2700 Loch Raven Rd	21218	N/A	DWO	Jones Falls	4:35	11:10 AM - 3:45 PM	Heavy gray water	2750	Not relieved broke pipe used 4 inch pump for bypass pumping	N/A	191847

## SSO Notification List

April 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
33	4/12/2014	3515 Rosekemp Ave	21214	Roots	DWO	Herring Run	1:39	1:36 PM - 3:15 PM	Sewer water, paper debris	495	Pressure jet relieved M/L choke	UAMD	191859
34	4/13/2014	251 N Monroe St	21223	Rags, grease	DWO	Gwynns Falls	14:41	04/13/14 7:19 PM - 04/14/14 10:00 AM	Heavy gray water	1762	Relieved M/L choke with pressure truck 250ft of 6in san M/L T/O for CCTV	CCTV	191909
35	4/13/2014	301 Scott St	21230	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Electric machine relieved choke	UAMD	191883
36	4/13/2014	3044 Guilford Ave	21218	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet around clean out	Evidence of Overflow	Used elec mach	UAMD	191900
37	4/13/2014	3116 Brighton St	21216	Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Rags-paper	Evidence of Overflow	Used sewer jet	UAMD	191894
38	4/13/2014	4814 Sunbrook Ave	21206	N/A	DWO	Back River	2:30	3:00 PM - 5:30 PM	N/A	75	Used sewer jet	UAMD	191892
39	4/13/2014	411 S Wickham Rd	21229	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper on ground around clean out	Evidence of Overflow	Used elec mach	UAMD	191827
40	4/14/2014	6 Hillside Rd	21210	Rags	WVO	Jones Falls	3:27	4:00 PM - 7:27 PM	Gray colored water	207	Used sewer jet	UAMD	191950
41	4/14/2014	1905 W Rogers Ave	21209	Rags, roots, grease	WVO	Jones Falls	17:02	04/14/14 4:59 PM - 04/15/14 10:00 AM	Heavy gray water	5110	Relieved M/L choke with pressure truck 300ft of 6in M/L T/O for CCTV	CCTV	191982
42	4/15/2014	5302 Denmore Ave	21215	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	Gray Water	Evidence of Overflow	Left plumber notice locate or install clean out closer	UAMD	192039
43	4/15/2014	5201 York Rd	21212	Grease	WVO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Drain cleaning machine relieved H/C choke	UAMD	192002
44	4/15/2014	2809 Boston St	21224	Heavy rain	WVO	Baltimore Harbor	16:22	04/15/14 4:33 PM - 04/16/14 8:55 AM	Water	4910	Wait for rain event to stop	N/A	192062
45	4/16/2014	N Gay St & E Biddle St	21213	Rags, grease, infiltration	DWO	Patapsco	2:02	10:03 AM - 12:05 PM	Sewer water	610	Pressure jet relieved M/L choke	UAMD	192088
46	4/16/2014	3537 Old York Rd	21218	Infiltration	DWO	Herring Run	15:13	04/16/14 9:35 PM - 04/17/14 12:48 PM	Sewer water	9130	Turned job over to utility engineering	N/A	192167
47	4/16/2014	4510 Bonner Rd	21216	Rags, grease	DWO	Gwynns Falls	1:41	12:49 PM - 2:30 PM	Heavy gray water	505	Relieved M/L choke with pressure truck 400ft of 8in san M/L T/O for CCTV	CCTV	192110
48	4/16/2014	601 E 36th St	21218	Infiltration/Inflow	DWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Turned job over to utility engineering	N/A	192165
49	4/16/2014	2106 Harford Rd	21218	Infiltration/Inflow, Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Left a plumbers notice choked inside	N/A	192128
50	4/17/2014	706 Monroe St	21217	Rags, grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved M/L choke with pressure truck 250ft of 8in T/O for CCTV	N/A	192227
51	4/17/2014	1327 W Fayette St	21223	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel with Elec-Misch 45ft Elec. cable	UAMD	192237
52	4/17/2014	Overland Ave & Ivy Ave	21214	Infiltration, debris	DWO	Herring Run	1:51	8:21 AM - 10:12 AM	Sewer water	555	Pressure jet relieved M/L choke	UAMD	192173
53	4/17/2014	1027 N Carey St	21217	Rags, grease, sand, gravel, rocks	DWO	Jones Falls	2:30	8:00 PM - 10:30 PM	Water running down alley	75	Used sewer jet	UAMD	192257
54	4/17/2014	1424 Mount Royal Ave	21217	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet around clean out and sidewalk	Evidence of Overflow	Used elec. mach.	UAMD	192252
55	4/18/2014	519 N Streeper St	21205	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with elec. mach.	UAMD CCTV	192297
56	4/18/2014	2800 Rosalind	21215	Rags, roots	DWO	N/A	1:20	1:40 PM - 3:00 PM	N/A	160	Relieved with pressure truck	UAMD CCTV	192305
57	4/19/2014	411 S Wickham Rd	21229	Rags, roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 60ft of 6in T/O for CCTV	N/A	192387
58	4/19/2014	1532 E Biddle St	21213	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 30ft of 6in T/O for CCTV	N/A	192372
59	4/20/2014	4517 Schenley Rd	21210	Rags, roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Rel with 123ft Elec machine cables	UAMD	192448
60	4/21/2014	1009 Appleton St	21217	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with Elec mach 15ft of 6in T/O CCTV	N/A	192480
61	4/21/2014	1809 Thornbury Rd	21209	Rags, roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with Elec mach 90ft of 6in	N/A	192491
62	4/21/2014	6647 Belair Rd	21206	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water, paper debris	Evidence of Overflow	Drain cleaning machine relieved H/C choke	UAMD	192590
63	4/22/2014	1104 Wood Heights Ave	21211	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	Toilet Paper	Evidence of Overflow	Ran 30ft Elec. Machine	UAMD	192604
64	4/22/2014	3205 Stafford St	21229	Pipe break	WVO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Ran 21ft Elec machine, brought back mud, Turn over and make repairs & bypass	UAMD	192564
65	4/22/2014	3330 Henry G Park Jr Cir	21215	Rags	WVO	Patapsco	3:03	2:37 PM - 5:40 PM	Heavy Gray Water	549	Relieved M/L choke with pressure truck 300ft of 8in san m/L T/O for CCTV	CCTV	192630
66	4/23/2014	5006 Midwood Ave	21212	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet Paper	Evidence of Overflow	Ran 60ft. Elec Machine	UAMD	192720
67	4/24/2014	3205 Stafford Rd	21229	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Bypass pumping for repair	N/A	192792

**SSO Notification List**

**April 2014**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
68	4/24/2014	3917 Boarman Ave	21215	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Relieved house conn choke with Elec. Mach. 45ft of 6in CCTV 4ft bottom 48ft to main	N/A	192808
69	4/24/2014	4517 Schenley Rd	21210	Pipe break	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Left plumber note locate of install cleanout T/O M.L. to CCTV	N/A	192804
70	4/25/2014	1902 Boone St	21218	Rags, grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved H/C choke	UAMD	192901
71	4/25/2014	3101 Pulaski Hwy	21224	Grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Drain cleaning machine relieved H/C choke	UAMD	192932
72	4/26/2014	1327 W Fayette St	21223	Rags, roots	WWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Ran elec. machine 30ft relieved house conn choke clear	UAMD	192982
73	4/26/2014	2804 Springhill Ave	21215	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Rel. HC 45ft Elec-Machine cable	UAMD	192985
74	4/26/2014	5107 Herring Run Dr	21214	Roots, debris	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Rel with 45ft Elec-machine cables	UAMD	192989
75	4/27/2014	2106 Harford Rd	21218	Rags, debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Ran 30ft. Elec-Machine cables	UAMD	193032
76	4/27/2014	5209 Midwood Ave	21212	Rags, roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Ran 30ft Elec-Machine cable	UAMD	193024
77	4/28/2014	2020 Hollins Ferry Rd	21230	Rags, roots, grease	WWO	N/A	4:59	11:01 AM - 4:00 PM	Heavy gray water	897	Relieved M/L choke with pressure truck 300ft of 8in san M/L T/O for CCTV	N/A	193107
78	4/29/2014	4104 Penhurst Ave	21215	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	Wet, rain, paper	Evidence of Overflow	Used Elec. Machine	UAMD CCTV	193249
79	4/30/2014	E 26th St & Charles St	21218	Pipe break, heavy rain	WWO	Jones Falls	1:14	4:21 PM - 5:35 PM	Clear gray water	1110	Set bulkhead in place over pumping, set over pumping in place	N/A	193509
80	4/30/2014	4021 Fairview Ave	21216	Rags, grease	WWO	Gwynns Falls	2:05	10:55 AM - 1:00 PM	Heavy gray water	1250	Relieved M/L choke with pressure truck 250ft of 8in over changing M/L T/O for CCTV	CCTV	193300
81	4/30/2014	900 Rutland Ave	21205	Heavy rain, Rocks	WWO	Baltimore Harbor	19:52	04/30/14 12:38 PM - 05/01/14 8:30 PM	Sewer water	29800	Wait for rain event to stop	N/A	193328
82	4/30/2014	1800 S. Clinton St	21224	Heavy rain, l/I	WWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Wait for rain event to stop	UAMD	314413
83	4/30/2014	1901 Falls Road	21217	Heavy rain	WWO	Jones Falls	21:33	04/30/14 10:27 AM - 05/01/14 8:00 AM	N/A	32325	"Over charging m/I"	N/A	193326
84	4/30/2014	3004 Biddison Ln	21206	Heavy rain, l/I	WWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Wait for rain event to stop	N/A	314304
85	4/30/2014	3901 Belair Rd	21206	Heavy rain, l/I	WWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Wait for rain event to stop	N/A	314522
86	4/30/2014	Cross Country Blvd & Dale Rd	21209	Heavy rain, l/I	WWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Wait for rain event to stop	N/A	314747
87	4/30/2014	E 26th St & N. Charles St-1000+ gallons	21218	Pipe break, heavy rain	WWO	N/A	26:00	04/30/14 4:00 PM - 05/01/14 6:00 PM	Clear gray water	39000	Set bulkhead in place over pumping, set over pumping in place	Set over pumping in place	193509
88	4/30/2014	Harford Rd & Argonne Dr	21214	Heavy rain, l/I	WWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Wait for rain event to stop	N/A	314547
				# WWO	42				TOTAL	143763	EVIDENCE ONLY	56	