

SSO Notification List

December 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	12/2/2013	2114 Bank St	21231	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Ran 30 ft. Elec. Machine cable	UAMD	116525
2	12/3/2013	2231 Rogene Dr	21209	Rags, Roots, Vandalism	DWO	Jones Falls	4:40	10:50 AM - 3:30 PM	Heavy Gray Water	560	Relieved house connection choke with pressure truck, 200ft of 6 in house connection T/O for CCTV	N/A	116568
3	12/4/2013	800 E Coldspring Ln	21212	Roots	DWO	Herring Run	1:45	9:57 AM - 11:42 AM	Gray Water	210	Relieved with pressure truck	UAMD Investigate/CCTV	116619
4	12/4/2013	2200 Cecil Ave	21218	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around clean out	Evidence of Overflow	Used elec. mach.	UAMD CCTV	116627
5	12/4/2013	2114 Bank St	21231	Unknown	DWO	Inner Harbor	9:00	11:30 AM - 8:30 PM	Wet paper on side walk	270	Used elec. mach.	UAMD CCTV	116608
6	12/9/2013	1401 Argyle Ave	21217	Rags, Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved M/L choke with pressure truck 200ft of 8in t/o for CCTV, 2ft water in basement bypass pumping	N/A	116774
7	12/9/2013	1911 W Mulberry St	21223	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around cleanout	Evidence of Overflow	Used Elec. Mach.	UAMD CCTV	116795
8	12/9/2013	447 Brunswick St	21223	Rags, Grease	WVO	Gwynns Falls	0:30	11:00 PM - 11:30 PM	Gray colored water	30	Used sewer jet	UAMD	116812
9	12/19/2013	2836 Maryland Ave	21218	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray colored water	Evidence of Overflow	Used sewer jet	Left plumbers notice, T/O to health dept.	117219
10	12/23/2013	4219 Woodlea Ave	21206	Roots, Trash	WVO	N/A	Not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Cabled line with elec.	UAMD	117350
11	12/19/2013	525 Hurley Ave	21223	Rags, Grease, Heavy Rain	DWO	N/A	Not Witnessed	Overflow not Witnessed	Debris	Evidence of Overflow	N/A	UAMD	Unknown
12	12/23/2013	W North Ave & McCulloh St	21217	Rags, Roots, Grease	WVO	Patapsco	2:21	1:12 PM - 3:34 PM	Heavy Gray Water	423	Relieved M/L choke with Pressure truck, 200ft. of 8in. san M/L T/O for CCTV	N/A	117374
13	12/23/2013	3304 W North Ave	21216	Rags, Grease	WVO	Patapsco	1:12	11:48AM - 1:00 PM	Heavy Gray Water	240	Relieved M/L choke with pressure truck, 275ft. of 8in. san M/L T/O for CCTV	N/A	117364
14	12/23/2013	Liberty Heights Ave & Carsdale Ave	21207	Rags, Grease	WVO	Patapsco	0:49	11:11 AM to 12:00 PM	Heavy Gray Water	147	Relieved M/L choke with pressure truck, 495ft. of 8in. san T/O for CCTV	N/A	117360
15	12/23/2013	406 Cambria St	21225	Grease	WVO	Patapsco	Not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Relieved M/L choke with pressure truck, 50ft. of 8in. T/O for CCTV	N/A	117361
16	12/20/2013	4333 Eldone Rd	21229	Rags, Roots	DWO	Patapsco	:60	1:25PM - 2:25 PM	Gray Water	60	Pressure truck flush 150ft. pressure hose	UAMD CCTV M/L	117264
17	12/17/2013	200 E 32nd St	21218	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	Sidewalk Wet	Evidence of Overflow	Used Elec. Mach. pump	UAMD CCTV	117125
18	12/18/2013	4530 Fairfax Rd	21216	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Ran 45ft Elec-Machine cable	UAMD	117157
19	12/26/2013	3812 Reisterstown Rd	21215	Roots, Debris	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel. 45ft. Elec.-Mach. Cable	UAMD	117455
20	12/26/2013	810 S Caton Ave	21229	Rags, Grease	WVO	Patapsco	0:39	2:21 PM - 3:00 PM	Heavy Gray Water	117	Relieved M/L choke with pressure truck, 50ft. of 8in. T/O for CCTV	N/A	117468
21	12/26/2013	2114 E Fayette St	21231	Rags, Sticks	WVO	N/A	Not Witnessed	Overflow not Witnessed	wet paper	Evidence of Overflow	Used Elec. Mach.	UAMD	117478

SSO Notification List

December 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
22	12/26/2013	4809 Erdman Ave	21205	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	wet paper	Evidence of Overflow	Used Elec. Mach.	N/A	117472
23	12/26/2013	3309 Piedmont Ave	21216	Sand, Clay, Mud	WWO	N/A	Not Witnessed	Overflow not Witnessed	wet paper	Evidence of Overflow	Used Elec. Mach.	UAMD	117469
24	12/26/2013	2850 Fleet St	21231	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	water	Evidence of Overflow	N/A	UAMD	77789
25	12/24/2013	1210 Seminole Ave	21229	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	N/A	UAMD	117414
26	12/12/2013	1800 Spence St	21230	Rags, Roots	DWO	Patapsco	1:13	8:47 AM - 10:00 AM	Heavy Gray Water	146	Relieved House Conn. choke with pressure truck, 250 ft. of 8 in. san. M/L T/O for CCTV	N/A	116904
27	12/13/2013	2613 E Biddle St	21213	Rags, Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around cleanout	Evidence of Overflow	Used Elec. Mach.	UAMD CCTV	116942
28	12/14/2013	100 W 39th St	21210	Unknown	WWO	Patapsco	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	N/A	UAMD	116986
29	12/15/2013	2900 Rosalind Ave	21215	Rags, Grease, Debris	DWO	Patapsco	2:40	12:20 PM - 3:00 PM	Heavy Gray Water	360	Relieved M/L choke with pressure truck 100ft. of 8in. T/O for CCTV	N/A	117025
30	12/19/2013	1400 E Northern Pkwy	21239	Rags, Roots, Grease, Debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris, feces, sewer water	Evidence of Overflow	Pressure jet relieved M/L choke	UAMD	117478
31	12/27/2013	1703 N Payson St	21217	Grease	DWO	Patapsco	2:35	9:12 AM - 11:47 AM	Heavy Gray Water	334	Relieved M/L choke with pressure truck, 300ft. of 10in. san M/L T/O for CCTV	N/A	117491
32	12/26/2013	2801 Beechland Ave	21214	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	Water in yard by cleanout	Evidence of Overflow	Used Elec. Mach.	By-pass Pump	117519
33	12/30/2013	3128 Weaver Ave	21214	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper wet around cleanout	Evidence of Overflow	Used Elec. Mach.	UAMD	117634
34	12/13/2013	4300 Edgehurst Rd	21210	Rags, Roots, Debris	DWO	Patapsco	5:48	7:00 AM - 12:48 PM	Heavy Gray Water	1044	Relieved M/L choke with pressure truck in MH, T/O for CCTV	N/A	Unknown
35	12/15/2013	5500 Greenspring Ave	21209	Rags, Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris, Feces	Evidence of Overflow	N/A	UAMD	117026
36	12/16/2013	205 S Fulton Ave	21223	Rags, Debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Ran 45 ft. Elec-Machine cable	N/A	117054
37	12/13/2013	2810 Pinewood Ave	21214	Roots	DWO	N/A	1:06	9:45 AM - 10:51 AM	Sewer Water	132	Drain cleaning machine relieved h/c choke	UAMD	116936
38	12/16/2013	4300 Orchard Ridge Blvd	21213	Roots, Debris	DWO	N/A	26:10	10:30 AM 12/16/13-12:40PM 12/17/13	Sewer Water, Paper Debris	7850	Pressure jet relieved m/l choke	UAMD	117083
39	12/17/2013	100 W 39th St	21210	Rags, Roots	WWO	Patapsco	3:28	8:00 AM - 11:38 PM	Heavy Gray Water	1090	Relieved M/L choke with hook rods, T/O for CCTV	N/A	173999
40	12/17/2013	1622 McCulloh St	21217	Rags, Roots	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Ran 30ft. Elec. Machine cables	UAMD	117123
41	12/11/2013	4335 Eldone Rd	21229	Rags, Grease	DWO	Gwynns Falls	3:00	9:30 AM - 12:30 PM	Gray colored water	900	Used sewer jet	UAMD	116897
42	12/16/2013	2735 Rayner Ave	21216	Rags, Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer Water, Paper Debris	Evidence of Overflow	Drain cleaning machine cleaned house connection & sewer rodder cleaned mainline	UAMD	117078

SSO Notification List

December 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
43	12/19/2013	1338 Sherwood Ave	21239	Rags, Roots	DWO	Jones Falls	0:60	7:30 AM - 8:30 AM	Gray colored water	60	Used sewer jet	UAMD	117225
44	12/19/2013	3210 Elmora Ave	21213	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet around cleanout	Evidence of Overflow	Used Elec. Mach.	UAMD	117217
45	12/19/2013	133 S Loudon	21229	Rags, Debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Ran 30ft. Elec. Machine cable	UAMD	117199
46	12/20/2013	3302 The Alameda	21218	Rags, Roots	DWO	N/A	0:60	6:30 PM - 7:30 PM	Wet Paper	30	Used Elec. Mach.	UAMD	117267
47	12/30/2013	4419 Mannasota	21206	Grease	DWO	Patapsco	12:26	10:54 Pm 12/30/13 - 11:20 AM 12/31/13	Gray Water	1492	Pressure truck flush main line rel. 25ft. pressure hose	CCTV Mainline	117651
48	12/31/2013	6541 Eastern Ave	21224	Rags, Grease, Debris	DWO	Patapsco	19:29	3:54 PM 12/31/13 - 11:23 AM 1/1/14	Heavy Gray Water	5845	Relieved M/L choke with pressure truck, 500ft. of 15in. sna M/L T/O for CCTV	N/A	117686
49	12/31/2013	1705 Bloomingdale Rd	21216	Roots	DWO	N/A	2:00	6 :00 PM - 8:00 PM	Gray colored water	60	Used Elec. Mach.	UAMD	117683
				# WWO	20				TOTAL	21400	EVIDENCE ONLY	27	