

SSO Notification List

June 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	6/1/2013	2211 Division St	21217	Rags, Grease	DWO	Jones Falls	1:39	3:10PM - 4:49PM	Grease Rags	198	Used Pressure Truck Relieved	UAMD Investage	160554
2	6/3/2013	207 N Castle St	21231	Rags	WVO	None	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Relieved w/electric machine	Refer to UAMD	160678
3	6/3/2013	2201 Westfield Ave	21214	Other: Mud	WVO	None	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Relieved w/electric Machine	UAMD	160665
4	6/4/2013	2509 Marbourne Ave	21230	Roots	DWO	None	Not Witnessed	Overflow not Witnessed	Paper Debris, Feces	Evidence of Overflow	Relieved w/electric machine	Refer to UAMD	160721
5	6/4/2013	2819 Westfield Ave	21214	Rags	DWO	None	Not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Relieved w Electric Machine	Refer to UAMD	160751
6	6/4/2013	3624 Roland Ave	21211	Rags	DWO	None	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieve Elec Machine 60ft	UAMD	160728
7	6/5/2013	3119 Baker St	21216	N/A	DWO	None	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Left Notice to Obtain Entrance	N/A	160807
8	6/5/2013	3208 Taney Rd	21215	Other Debris	DWO	None	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	N/A	Relieve House Conn Choke	160772
9	6/6/2013	1704 Rogers Ave	21215	Power Loss	WVO	None	1:00	12:00PM - 1:00PM	N/A	60	Used Vac Con Do Suck Out	MH ML Choke T/O to Contractors	160844
10	6/7/2013	110 W 39th St	21210	Sump, Other: Pipe Break	WVO	Jones Falls	9:30	10:00AM - 7:30PM	Gray Water	28500	By Pass Pump Making Repairs ro Pipes	Making Repairs to Pipe Turn Over to UAMD	160866
11	6/7/2013	1808 Fairbank Rd	21209	Roots	WVO	None	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieve House Conn Choke Elec Machine	UAMD	160878
12	6/7/2013	3101 Pulaski Hwy	21224	Rags, Grease	WVO	Dundalk	4:00	2:30PM - 6:30PM	Gray Water	960	Used Pressure Truck	Will Get TV'd and UAMD Investigate	160893
13	6/7/2013	666 E 27th St	21218	Roots	WVO	Jones Falls	4:15	2:30PM - 6:45PM	Sewer Water	3825	Pressure Jet Relieved the Mainline Choke	UAMD Investigation	160895
14	6/8/2013	1802 Guilford Ave	21211	N/A	DWO	None	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	N/A	N/A	160920
15	6/8/2013	3701 Erdman Ave	21213	Grease, Trash	DWO	Herring Run	11:51	6/7/13 10:22AM - 6/8/13 10:13AM	Gray Muddy Water	1422	Flush with Pressure Truck	Routine Cleaning	160922
16	6/9/2013	666 E 27th St	21213	N/A	DWO	None	Not Witnessed	overflow not Witnessed	N/A	Evidence of Overflow	N/A	N/A	160898
17	6/10/2013	4400 Kathland Ave	21217	Heavy Rain	WVO	Gwynns Falls	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	N/A	N/A	161065
18	6/11/2013	620 E 30th St	21218	Pipe Break	DWO	None	Not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Used Elec Mach	Left Plumbers Notice Clean Out	161114
19	6/11/2013	1901 Falls Rd	21211	Heavy Rain	DWO	Jones Falls	Not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	N/A	N/A	161180
20	6/11/2013	2525 Insulator Dr	21230	Rags, Roots	DWO	Inner Harbor	1:35	12:55PM - 2:30PM	Gray Colored Water	47.5	Used Press Machine	UAMD Investigation	161110
21	6/11/2013	2920 Benson Ave	21223	Heavy Rain	DWO	Gwynns Falls	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Waited for Rain Event to Stop	N/A	161153
22	6/11/2013	3008 Wilkens Ave	21223	Other Debris	DWO	N/A	Not Witnessed	overflow not Witnessed	N/A	Evidence of Overflow	Evidence of Overflow	Overcharging ML	161111
23	6/11/2013	4209 Wickford Ave	21210	Rags, Other Debris	DWO	Jones Falls	1:52	9:45 AM - 11:37AM	Heavy Gray Water	560	Relieve Pressure Truck	T/O UAMD Investigate	161088
24	6/11/2013	540 Hurley Ave	21223	Rags, Heavy Rain, Other Debris	DWO	None	Not Witnessed	overflow not Witnessed	N/A	Evidence of Overflow	Evidence of Overflow	Over Chargin ML due to Heavy Rain	SR# 110803
25	6/12/2013	1945 W Lafayette Ave	21217	N/A	WVO	None	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	15ft Elec Mach	UAMD TV 3.5ft to Bottom	161188
26	6/12/2013	2105 Erdman Ave	21218	Roots, Grease	WVO	N/A	1:00	11:30AM - 12:30PM	Gray Colored Water	60	Used Elec Mach to Relieve Choke	CCTV Clear	161205
27	6/13/2013	119 Overhill Ave	21210	Other, Debris	WVO	Jones Falls	19:10	6/13/13 5:30PM - 6/14/13 12:40PM	Sewer Water	5750	Pressure Jet Relieved the Mainline Choke	Turn Over to UAMD	161307
28	6/13/2013	412 George St	21201	Other Improper Installation	WVO	Inner Harbor	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Turned Over to the in-house Contractor	N/A	161270
29	6/14/2013	508 Hanover St	21201	N/A	WVO	None	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Ran 90' of electric machine cable w/auger	UAMD	161311
30	6/14/2013	Key Hwy & Webster St	21230	Grease	WVO	Inner Harbor	1:37	7:18PM - 8:55PM	Grease, Sewer Water	485	Pressure Jet Relieved ML Choke	Turned Over to UAMD	161362
31	6/15/2013	201 E 31st St	21218	Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet Paper	Evidence of Overflow	Turn Over to Housing To Cut Water Off	Turn Over to UAMD	161388
32	6/16/2013	1236 Braddish Ave	21216	Rags, Roots	WVO	N/A	2:05	2:55PM - 5:00PM	Heavy Gray Water	375	Relieved with Electric Machine	UAMD Investigate	161422
33	6/16/2013	1415 Clarkson St	21230	Rags, Other, Debris	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved the House Connection Choke	Turn Over to UAMD	161444
34	6/17/2013	501 E 36th St	21218	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine, Relieved the HC Choke	UAMD	161440
35	6/18/2013	1112 Wood Heights Ave	21211	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Rel, 30ft Elec Machine	UAMD	161513
36	6/18/2013	1937 E North Ave	21213	Rags	WVO	Baltimore Harbor	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved House Connection Choke	UAMD	161532
37	6/20/2013	810 Glen Allen Dr	21229	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke	with Elec Mach 45ft TV 6.0ft	161604
38	6/20/2013	1625 Stonewood Rd	21239	Rags, Grease	DWO	Herring Run	0:10	9:00PM - 9:10PM	Sewer Water, Grease, Feces	50	Relieved w/Hand Rods	Turned Over to UAMD	161645
39	6/20/2013	1008 Poplar Hill Rd	21210	Rags, Roots	DWO	Gwynns Falls	39:05	6/20/13 8:45PM - 6/22/13 11:50AM	Sewer Water	4690	Pressure Jet Relieved the M/L Choke	Turned Over to UAMD	161647
40	6/20/2013	1100 E 20th St	21202	Grease, Other, Debris	DWO	Jones Falls	1:45	12:30PM - 2:15PM	Sewer Water, Grease	525	Pressure Jet Relieved M/L Choke	Turned Over to UAMD	161610
41	6/20/2013	Ensor St & E Madison St	21202	Rags, Grease	DWO	Jones Falls	1:33	9:42AM - 11:15AM	Sewer Water, Grease	465	Pressure Jet Relieved the M/L Choke	Turned Over to UAMD	161600
42	6/23/2013	3100 S Hanover St	21225	Rags, Grease	WVO	Patapsco	1:00	1:24PM - 2:24PM	Heavy Gray Water	600	Relieved ML Choke with Press Truck 200 Ft of 12inc San M.L.	T/O for CCTV	161733
43	6/24/2013	2016 E 31st St	21218	Roots	WVO	N/A	Not Witnessed	overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved the HC Choke	UAMD	161805
44	6/26/2013	1937 E North Ave	21213	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with Electric Machine	UAMD Investigate/ Evidence Only	161924

SSO Notification List

June 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
45	6/26/2013	5423 O'Donnell St	21224	Rags, Grease	WWO	Dundalk	1:25	10:15AM - 11:40AM	Heavy Gray Water	425	Pressure Jet Relieved Choke	UAMD Investigate	161869
46	6/28/2013	Alpine Rd & Wilmslow Rd	21210	Rags, Roots	WWO	Jones Falls	1:03	11:57AM - 1:00PM	Heavy Gray Water	189	Relieved M/L Choke with Press Truck 200ft of 6inch	T/O for CCTV	162024
47	6/29/2013	2863 Maudlin Ave	21230	Rags	DWO	N/A	Not Witnessed	overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 45 ft TV 60:2 Bottom	N/A	162071
				# WWO	23				TOTAL	49,187	EVIDENCE ONLY	28	