

**SSO Notification List**

**May 2013**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	5/1/2013	1615 Ashburton St	21216	N/A	DWO	None	Overflow Not Witnessed	overflow not Witnessed	N/A	Evidence of Overflow	Ran 28ft of Elec Mach is Not Relieved	PM	159887
2	5/1/2013	2313 Allendale Rd	21216	N/A	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 60ft of 6inch	TV 1.6 Bottom 31.8	158930
3	5/1/2013	6708 Cross Country Blvd	21215	Rags, Roots	DWO	Jones Falls	1:37	2:06PM - 3:45PM	Heavy Gray Water	97	Relieved ML Choke with Press Truck	N/A	158970
4	5/1/2013	Ashland Ave & N Caroline St	21205	Rags, Grease	DWO	Jones Falls	1:15	5:10PM - 6:25PM	Sewer Water	375	Pressure Jet Relieved M/L Choke	Turned Over to CCTV	158990
5	5/2/2013	931 Wilmington Ave	21223	Roots	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 30ft of 6 inch	TV 8.8ft Bottom 9.8ft	159020
6	5/2/2013	3212 Juneau Pl	21214	Rags, Trash	DWO	Herring Run	0:40	9:40AM - 10:20AM	Brown + Gray Colored Water	200	Jetted Line with Pressure Truck	Line to be TV ASAP	159016
7	5/2/2013	2115 Ridgehill Ave	21217	Other Debris	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 9 ft of 6 inch	TV 9:ft	159034
8	5/2/2013	305 Somerset Rd	21210	N/A	DWO	None	Overflow Not Witnessed	overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Press Truck 30ft of 6inch	Two 7.0 ft Bottom 14.5	159058
9	5/3/2013	6200 Holabird Ave	21224	Rags, Grease	DWO	Inlet (Back River)	0:50	10:30AM - 11:30AM	Gray Colred Water-Paper	60	Used Press Machine to relieve Mainline will have mainline	Will Have Mainline CCTV	159077
10	5/3/2013	428 E Preston St	21215	Rags, Grease, Trash	DWO	None	Overflow Not Witnessed	overflow not Witnessed	Rags, Debris, Grit	Evidence of Overflow	Regular Flushing	N/A	159104
11	5/5/2013	810 N Hilton St	21229	Rags	DWO	Gwynns Falls	35:10	5/5/13 10:50PM - 5/7/13 10:00AM	N/A	2110	Relieved M/L Choke with Press Truck 25ft of 8inch	T/O for CCTV	159183
12	5/6/2013	2218 Deerfern Cres	21209	Roots	WVO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 45ft of 6inch	T/O for CCTV	159188
13	5/6/2013	902 Reverdy Rd	21212	Roots	WVO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 30ft of 6 inch	TV 6.7 Bottom 7.9	159220
14	5/6/2013	4605 Briarcliff Rd	21229	Rags, Roots	WVO	Gwynns Falls	0:55	7:05PM - 8:00PM	Heavy Gray Water	275	Relieved ML Choke with Press Truck ft of 8 inch San ML	T/O for CCTV	159229
15	5/7/2013	574 Orchard St	21201	Grease	WVO	High Level	1:22	11:53AM - 1:15PM	Heavy Gray Water	164	Relieved ML Choke with Press Truck 250ft of 8 inch	T/O for CCTV	159286
16	5/7/2013	1505 Woodbourne Ave	21239	Rags, Roots	WVO	None	Overflow Not Witnessed	Overflow not Witnessed	Clear Water	Evidence of Overflow	Cleaned Line with Elec Mach	Line to be TV'd ASAP	159278
17	5/9/2013	2723 Presbury St	21216	Roots, Other Debris	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 30ft of 6inch	No TV Cap In Conn	159423
18	5/10/2013	2133 ColdSpring Ln	21214	Grease	WVO	Herring Run	2:54	6:21PM - 9:15PM	Sewer Water, Feces	1740	Pressure Jet Relieved Choke	Turned Over to CCTV	159517
19	5/11/2013	Loch Raven Blvd & Winston Ave	21212	Rags	WVO	Herring Run Stream	2:15	10:00AM - 12:15PM	Gray Water	270	Used Pressure Truck	Will Have Mainline TV	N/A
20	5/11/2013	2479 Druid Hill Ave	21217	Rags, Grease	WVO	Jones Falls	0:55	1:15PM - 2:10PM	Gray Water Rags	165	Used Pressure Truck to Relieve	Will Get TV'd	159524
21	5/11/2013	4406 Kathland Ave	21207	Rags, Grease	WVO	None	0:50	8:00PM - 9:00PM	Gray Colored Water	60	Used	Will have Mainline CCTV	159534
22	5/11/2013	5213 Putney Wat	21212	Roots	WVO	None Inlet	0:50	7:00PM - 8:00PM	Gray Colored Water	60	Used Press MACH to Relieve Mainline	Will Have Mainline CCTV and Cleaned with Sewer Rodder	159533
23	5/12/2013	1234 Braddish Ave	21207	Rags, Roots	WVO	None	Overflow Not Witnessed	Overflow not Witnessed	Wet Paper on Ground Around Clean Out	Evidence of Overflow	Used Elec Mach to Relieve Conn	CCTV Clean	159558
24	5/12/2013	4600 Briarcliff Rd	21229	Rags, Grease	WVO	Gwynns Falls	3:50	11:10AM - 3:00PM	Gray Water and Rags	2300	Used Pressure Truck	Used Pressure Truck Will Get TV'd on 5/13/13	159549
25	5/12/2013	2603 Boone St	21218	Rags, Grease, Trash	WVO	None	Overflow Not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Cleaned Line with Elec Mach	Possible Grease Control	159541
26	5/13/2013	501 Edgevale Rd	21210	Leaking Water Meter	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Flushed Sewer Mainline	N/A	159752
27	5/17/2013	4023 Loch Raven Blvd	21218	Other Debris	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 30ft 6inch	TV 6.6	159841
28	5/20/2013	503 Edgevale Rd	21210	Roots	DWO	Jones Falls	1:04	9:56AM - 11:00AM	Heavy Gray Water	64	Relieved M/L Choke with Press Truck 250ft of 6 inch San ML	T/O for CCTV	159900
29	5/20/2013	2656 Miles Ave	21211	Roots	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 15ft of 6inch	CCTV	159905
30	5/20/2013	4707 Frederick Ave	21229	N/A	DWO	None	Overflow Not Witnessed	overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 10ft of 6inch	TV 5 Bottom	159918
31	5/21/2013	2712 Cylburn Ave	21215	Roots, Other Debris	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 30ft 0f 6inch	CCTV	159941
32	5/21/2013	3912 Liberty Heights Ave	21207	Roots, Grease	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Relieved M/L Choke with Press Truck 950 ft of 6inch San ML	N/A	159990
33	5/21/2013	3400 Park Heights Ave	21215	Rags, Grease	DWO	None	Overflow Not Witnessed	overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Relieved ML Choke with Press Truck 100ft of 8inch	T/O UAMD	159995
34	5/21/2013	5008 Loch Raven Blvd	21239	Rags, Trash	DWO	None	14:10	5/21/13 6:15PM - 5/22/13 10:25AM	Gray + Brown Colored Water	4850	Cleaned Line with Vaccon	Turned Over to UAMD	159985
35	5/22/2013	2313 Hamilton Ave	21214	Roots	WVO	None	Overflow Not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Cleaned with Elec Mach	Turned Over to UAMD	160020
36	5/25/2013	1227 Bentalou St	21216	Grease	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Electric Machine	UAMD Investigate	160172

**SSO Notification List**

**May 2013**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
37	5/26/2013	4307 N Charles St	21218	Roots, Grease	DWO	Jones Falls	2:00	12:30PM - 2:30PM	Gray Water	600	Pressure Jet Relieved	UAMD Investigate	160188
38	5/26/2013	4700 Falls Rd	21209	Grease	DWO	Jones Falls	14:31	5/26/13 6:59PM - 5/27/13 9:30AM	Sewer Water	21775	Pressure Jet Relieved Choke	Turned Over to UAMD	160204
39	5/27/2013	2308 Pennyroyal Ter	21209	Grease, Trash	DWO	None	Overflow Not Witnessed	overflow not Witnessed	Paper	Evidence of Overflow	Electric Machine/ UAM	Evidence Only	160220
40	5/27/2013	4303 N Charles St	21218	Rags, Roots	DWO	Jones Falls	0:40	8:05PM - 8:45PM	Sewer Water	200	Pressure Jet Relieved Choke	Turned Over to UAMD	160233
41	5/27/2013	1329 Medfield Ave	21211	Rags, Roots, Other Paper	DWO	None	Overflow Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke 45ft of 6 inch	T/O CCTV	160236
42	5/29/2013	2019 Barclay St	21202	Rags, Grease	DWO	None	1:00	9:30AM - 10:30AM	Light Gray Water	30	Relieved with Elec Mach	CCTV Clear	160333
43	5/30/2013	1714 N Calhoun St	21217	Rags, Other Debris	DWO	None	Overflow Not Witnessed	overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 30ft	T/O CCTV	160446
44	5/30/2013	6210 Holabird Ave	21224	Rags, Grease, Trash	DWO	Northwest Passage	1:30	11:35AM - 1:05PM	Brown + Gray Colored Water	270	Jetted Line with Vac Con	Turn Over to UMD	160443
				# WWO	14				TOTAL	35,665	EVIDENCE ONLY	24	